## Application of a genetic algorithm for calculating the capacitances on an insulator string

I.F. GONOS N. C. ILIA V.T. KONTARGYRI I.A. STATHOPULOS School of Electrical and Computer Engineering, High Voltage Laboratory National Technical University of Athens GREECE

igonos@ieee.org leta@power.ece.ntua.gr vkont@power.ece.ntua.gr stathop@power.ece.ntua.gr

*Abstract:* - The aim of this paper is the study of the distribution of the voltage along an insulator string. Insulator strings are used for the suspension of overhead transmission lines. This paper presents a method for the calculation of the capacitances on insulator strings using genetic algorithm. The simulation results have been compared with experimental results, which have been obtained in the High Voltage Laboratory of the National Technical University of Athens. The good agreement between experimental and computed results is a very strong indication for the validity and the correctness of the developed model.

Key words: - Insulator string, genetic algorithm, stray capacitance, cap-and-pin type porcelain insulator

### **1** Introduction

Insulator strings are used for the suspension of overhead transmission lines. Every insulator has an equivalent capacitance, which is equal for all the same insulators of the string. But the stray capacitances of each insulator to the high voltage conductor as well as to earth have different values for different positions of the insulator in the string.

The stray capacitance is the reason of the nonuniform distribution of the voltage across the string. Owing to the capacitances existing between the discs, conductor and ground the distribution of the voltage along the insulator is not uniform, the discs nearer the conductor being more highly stressed.

In recent years there is a rapidly growing interest in the mechanism of development of electrical arc in polluted insulators. Polluted insulators can trigger under certain circumstances the development of electrical arcs. which could cause serious disturbances in the proper operation of networks. This phenomenon that is called pollution flashover is still not completely clear. A great number of projects are carried out and many studies have been published all over the world concerning this phenomenon. In spite of these significant efforts it has become evident that there is not a fully acceptable explanation of the pollution flashover mechanism and that is the reason why there isn't still a general and efficient method in facing the problem.

Airborne pollutants due to natural or industrial or even mixed pollution cover the surface of the insulators. As the surface becomes moist because of rain, fog or dew, the pollution layer becomes conductive because of the presence of ionic solids. A leakage current flows through the conducting surface film generating heat, which tends to increase the film temperature most rapidly at those points where the current density is greatest, i.e. at narrow sections of the insulator, such as the area around the pin of the insulator. Eventually, the temperature in these areas approaches boiling point, and rapid evaporation of the moisture occurs producing dry areas.

# 2 Experimental apparatus and test results

The examined cap-and-pin type insulator is used in insulator strings for the suspension of 150 kV overhead transmission lines crossing coastal and industrial areas, with remarkably high pollution. The geometrical characteristics of the investigated insulator are the diameter, which is 254 mm, the height, which is 146 mm, and the creepage distance, which is 305 mm.

The aim of our experiments was the study of the distribution of the voltage across an insulator string. The test arrangement is shown in Fig. 1. It includes a 230 V self-transformer frequently found in industrial environments. Through this self-transformer, a 110V/55kV transformer is fed. The voltage is measured by two methods. The first method is using the voltmeter V<sub>1</sub> in the primary part of the transformer and then transforming the low voltage  $U_I$  in high voltage multiplying by the voltage

transformer ratio *a*. The second method is using an electrostatic voltmeter  $E_v$  and measuring the high voltage  $U_2$  in the secondary part of the transformer [1, 2]. The average  $U_{ti}$  of the two values is the voltage applied across the ten-insulator string:

$$U_{ti} = \frac{U_{1i} \cdot a + U_{2i}}{2}$$
(1)

The insulator string consists of ten individual insulators. In parallel with i-insulator is connected a sphere gap. The capacitance of the sphere gap is very small compared with the capacitance of the insulator, so it can be neglected.



Fig. 1: Experimental set-up.

Increasing the voltage  $U_t$ , which is applied to the insulator string, the sphere gap critical voltage  $U_d$  is being reached. The rate of the voltage  $P_i$ , which is applied in the i-insulator, is given by

$$P_i = \frac{U_d}{U_{t_i}} \cdot 100\% \tag{2}$$

The stray capacitances are the reason that the distribution of the voltage in each insulator is not uniform. Moving the sphere gap in each of the ten insulators and calculating the rates  $P_i$  for each insulator the critical voltage of the sphere gap is calculated by the equation



Fig. 2: The percentage voltage in each insulator.

The experiment has been repeated for several different insulator strings, which are consisting of ten discs with the same geometrical characteristics, but for different pollution levels. The experimental results for three of the investigated strings are shown in Fig. 2. One edge of the insulator string (1<sup>st</sup> insulator) is grounded and the other edge (10<sup>th</sup> insulator) is connected with the transmission line. The insulator's number, in Fig. 2, shows the position of the insulator at the string.

#### **3** Genetic Algorithm

Genetic algorithms were first introduced by John Holland for the formal examination of the mechanisms of natural adaptation [3], but since then the algorithms have been modified to solve computational problems in research. Modern genetic algorithms deviate greatly from the original form proposed by Holland, but their lineage is clear. Genetic algorithms are now widely applied in science and engineering as adaptive algorithms for solving practical problems. Certain kinds of problems are particularly suited to being tackled using a genetic algorithm approach. The general acceptance is that genetic algorithms are particularly suited to multidimensional global problems where the search space potentially contains multiple local minima. Unlike other methods, correlation between the search variables is not generally a problem. The basic genetic algorithm does not require extensive knowledge of the search space, such as solution bounds or functional derivatives. A task to which simple genetic algorithms are not suited is rapid local optimization; however, coupling the genetic algorithm with other techniques to overcome this problem is trivial. Whenever multidimensional systematic searching is the technique of choice, despite the fact that the large number of comparisons makes that approach intractable, a genetic algorithm should be considered the best choice for the reasons outlined in the sections below [3, 4].

This paper proposes a methodology, which uses the developed genetic algorithm for the calculation of the capacitances and the voltage distribution of an insulator string. This genetic algorithm has been developed using the software package Matlab. This genetic algorithm produces excellent results in several optimization problems [5-8]. It has been applied for minimization in multidimensional systems [5, 6], calculation of arc parameters for polluted insulators [7] and computation of the parameters of the ground structure [8]. The operation of genetic algorithm, which has been developed, is described in the flow chart of Fig. 3.



Fig. 3. The flow chart of our Genetic algorithm

#### 4 Calculation of capacitance

The calculation of the parameters of an insulator string is an optimization problem. For the computation of the three parameters (capacitance of each insulator C, stray capacitance to earth  $C_e$  and stray capacitance to the high voltage conductor  $C_h$  as they are shown in Fig. 4), the minimization of the function  $F_g$  is necessary:

$$F_{g} = \sum_{i=1}^{N} \frac{\left| P_{i}^{m} - P_{i}^{c} \right|}{P_{i}^{m}}$$
(4)

where  $P_i^m$  is the *i-th* measurement value of the rate of voltage, which is applied in the i-insulator, while  $P_i^c$  is the computed one. The computed value  $P_i^c$  is calculated using the equations (5-7) [9-11]:

$$P_i^{\mathcal{C}} = \frac{100}{1+m} \left\{ 1 + m \cdot \frac{\sinh(i \cdot \gamma)}{\sinh(n \cdot \gamma)} - \frac{\sinh((n-i) \cdot \gamma)}{\sinh(n \cdot \gamma)} \right\}$$
(5)

$$\gamma = \sqrt{\frac{C_e + C_h}{C}} \tag{6}$$

$$m = \frac{C_e}{C_h} \tag{7}$$



Fig. 4. The capacitances of the insulator string

The application of the genetic algorithm for the experimental results of string 2 (Fig. 2) with number of parents  $P_s$ =20, bit of binary number (size of chromosome) t=16, variables m=3, number of children  $N_c$ =4, parts for crossovers  $N_p$ =6, maximum number of iterations  $N_{max}$ =40 and probability of mutation  $P_m$  =5%. The application results finally converge to the optimum values C=148.965 pF,  $C_e$ =8.324 pF and  $C_h$ = 1.560 pF as the number of iterations increases (Fig. 5).

The whole procedure is shown in Fig. 5, where it becomes obvious that the algorithm converges rapidly to these values. The next step is to verify the validity of the genetic algorithm by applying the computed values of the capacitances to the experimental results of Fig. 2. The utilisation of the optimum values of the capacitances (Table 1) in the mathematical model results to the curves of the rate of the voltage  $P_i$ , which is applied in the i-insulator (Fig. 6). In this figure the results from other experiments (string 1 and string 3) are also presented. It may be pointed out that the computed values agree well with the experiments.

Table 1. Results of GA

	С	$C_e$	$C_h$	E
	[pF]	[pF]	[pF]	Γg
String 1	109.219	6.117	1.149	0.1916
String 2	148.965	8.324	1.560	0.1905
String 3	130.586	7.293	1.364	0.1901



Fig. 5. Convergence of the GA results (string 2)



Fig. 6. Comparison between experimental and simulation results

#### **5** Conclusions

The aim of this paper is the study of the distribution of the voltage across an insulator string. A method for the calculation of the capacitances on an insulator string using genetic algorithm is presented. The good agreement between experimental and computed results is a very strong indication for the validity and the correctness of the developed model and allow the limitation or even the elimination of the experiments needed for the calculation of voltage distribution across the insulator string. The limitation or elimination of experiments seems to be very significant since the execution of such experiments is time and money consuming has and as presupposition the availability of expensive equipment.

References:

- [1] International Electrotechnical Commission, *High-voltage test techniques. Part 1: General definitions and test requirements*, IEC 60060-1 (1989-11), 1989.
- [2] International Electrotechnical Commission, *High-voltage test techniques. Part 2: Measuring systems*, IEC 60060-2 (1994-11), 1994.
- [3] H. Holland, *Adaptation in natural and artificial systems*, University of Michigan Press. Reprinted in MIT Press, 1992.
- [4] D. E. Goldberg, *Genetic algorithms in search, optimisation, and machine learning*, Addison-Wesley, 1989.
- [5] I. F. Gonos, N. E. Mastorakis and M. N. S. Swamy "A Genetic Algorithm Approach to the Problem of Factorization of General Multidimensional Polynomials", *IEEE Transactions on Circuits and Systems, Part I*, vol. 50, No. 1, pp. 16-22, January 2003.
- [6] N. E. Mastorakis, I. F. Gonos and M. N. S. Swamy "Design of 2-Dimensional Recursive Filters using Genetic Algorithms", *IEEE Transactions on Circuits and Systems, Part I*, vol. 50, No. 5, pp. 634-639, May 2003.
- [7] I. F. Gonos F. V. Topalis and I. A. Stathopulos "A genetic algorithm approach to the modelling of polluted insulators", *IEE Proceedings Generation, Transmission and Distribution*, vol. 149, No. 3, pp. 373-376, May 2002.
- [8] I. F. Gonos, *Transient behaviour of grounding system*, PhD thesis, National Technical University of Athens, Greece, 2002 (in Greek).
- [9] D. Kind, K. Feser, *High voltage test techniques*, SBA Publications/Vieweg, 1999.
- [10] M.S. Naidu, V. Kamaraju, *High voltage engineering*, Mc Graw Hill, 1996, pp. 143-146.
- [11] M. Khalifa, *High voltage engineering*, Marcel Dekker Inc., 1990, pp. 444-447.

#### **Authors address:**

School of Electrical and Computer Engineering, Electric Power Department, High Voltage Laboratory, National Technical University of Athens, 9, Iroon Politechniou Str., GR 15780, Zografou Campus, Athens, GREECE

Tel.: +30 210772 3582, Fax: +30 210772 3504

E-mail: igonos@ieee.org; leta@power.ece.ntua.gr; vkont@power.ece.ntua.gr;

stathop@power.ece.ntua.gr